

# Mecklenburg County Common Code Defects

## Electrical

### Code Defects

Need Knockout Stoppers

### Code Description

110.12 Mechanical Execution of Work.

Electrical equipment shall be installed in a neat and workmanlike manner.

**(A) Unused Openings.** Unused cable or raceway openings in boxes, raceways, auxiliary gutters, cabinets, cutout boxes, meter socket enclosures, equipment cases, or housings shall be effectively closed to afford protection substantially equivalent to the wall of the equipment. Where metallic plugs or plates are used with nonmetallic enclosures, they shall be recessed at least 6 mm (¼ in.) from the outer surface of the enclosure.

***Disclaimer: There may be other ways to comply with the Code. If so, you are not required to use this method to comply with the Code. You may want to investigate other options, or consult with a design professional identifying an equally code compliant solution.***

### End Notes

National Electrical Code

National Electrical Code Committee and National Fire Protection Association Inc.

Anaheim, CA August 2, 2001